**The Construction Products Regulation 2011 (retained EU law EUR 305/2011) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020.**

**DECLARATION OF PERFORMANCE**

**No. U0033**

1. **Unique identification code of the product-type:**

   **Model number and Description:**

   55000-440 XP95 IS Analogue Addressable Intrinsically Safe Class A2S Heat Detector
   55000-440SIL XP95 IS Analogue Addressable Intrinsically Safe Class A2S Heat Detector

   **Approved Accessories:**

   45681-215 Intrinsically Safe Mounting Base

   **Product Type(s):**

   Heat Detectors – Point Detectors

2. **Intended use/es:**

   Point detectors for use in fire detection and fire alarm systems installed in and around buildings

3. **Manufacturer:**

   Apollo Fire Detectors Ltd,
   36 Brookside Road, Havant, Hampshire, PO9 1JR, United Kingdom

4. **Authorised representative:**

   N/A

5. **System of AVCP**

   System 1

6. **Designated Standard(s)**

   EN 54-5:2017 + A1:2018

   **UK Approved Body:**

   DBI Certification-UK Ltd (Approved Body 8504)



Apollo Fire Detectors Limited
36 Brookside Road, Havant, Hampshire, PO9 1JR, UK
t +44 (0)23 9249 2912 f +44 (0)23 9249 2754 e sales@apollo-fire.co.uk
www.apollo-fire.co.uk

Apollo Fire Detectors Ltd. Registered in England No. 1483208
Registered Office: 36 Brookside Road, Havant, Hampshire, PO9 1JR VAT Registration No. GB 339 0553 54

## 7 Declared performance

Table 1

| Detector Category (Heat Class): | Typical Application Temperature | Maximum Application Temperature °C | Minimum Static Response Temperature °C | Maximum Static Response Temperature °C |
|---|---|---|---|---|
| A2S | 25 | 50 | 54 | 70 |

**Table 2- Response time limits**

| Rate of rise of air temperature K min-1 | Cat A2S | | | |
|---|---|---|---|---|
| | Lower limit | | Uper limit | |
| | Min | S | Min | S |
| 1 | 29 | 0 | 46 | 0 |
| 3 | 7 | 13 | 16 | 0 |
| 5 | 4 | 9 | 10 | 0 |
| 10 | 2 | 0 | 5 | 30 |
| 20 | 1 | 30 | 3 | 13 |
| 30 | | 40 | 2 | 25 |

**Performance**

| **Essential characteristics** | **Clauses in EN 54-5:2017/ A1:2018** | **Regulatory classes** | **Performance** |
|---|---|---|---|
| **Operational reliability:** | | A2S | |
| Position of heat sensitive element | 4.2.1 | | The heat sensitive element(s) or at least part of it, except elements with auxiliary functions (e.g.characteristic correctors), are a distance ≥15mm from the mounting surface of the point heat detector. |
| Individual alarm indication | 4.2.2 | | Category A2S<br>The heat detector is provided with an integral red visual indicator and can remain identified until the alarm is reset. The visual indicator is visible from a distance of 6 m directly below the point heat detector,in an ambient light intensity up to 500 lx. |
| Connection of ancillary devices | 4.2.3 | | Open or short circuit failures of connection to ancillary device do not prevent the correct operation of the detector |
| Monitoring of detachable point heat detectors | 4.2.4 | | A fault condition is signaled when the detector is removed from the mounting base. |
| Manufacturer's adjustments | 4.2.5 | | It is not possible to change the maufacture´s settings expept by special means (e.g. a special code or tool, or by breaking or remove a seal). |
| Onsite adjustments of response behavior | 4.2.6 | | N/A |
| Software controlled detectors (when provided) | 4.2.7 | | N/A |

| | | | |
|---|---|---|---|
| **Nominal activation conditions/Sensitivity:** | | | |
| Directional dependence | 4.3.1 | | The response time of the point dectetor do not unduly depend on the direction of airflow around the point heat detector. |
| Static response temperature | 4.3.2 | | The response temperatures of the point heat detectors lie between the minimum and maximum static response temperatures, according to the category of the point heat detector in Table 1 above. |
| Response times from typical application temperature | 4.3.3 | | The response times of the point heat detector lie between the lower and upper response time limits for the appropriate point heat detector category in Table 2 above. |
| Response times from 25 °C | 4.3.4 | | The response time at 3 K $min^{-1}$ exceeds 7 min 13 s and the response time at 20 K $min^{-1}$ exceeds 1 min 0 s. |
| Response times from high ambient temperature | 4.3.5 | | No alarm or fault signal was given at high ambient temperatures appropriate to the anticipated service temepratures.<br>A2S<br>3 K $min^{-1}$, Lower limit, 1 min 20 s and upper limit 16 m.<br>20 K $min^{-1}$, Lower limit, 12 s and upper limit 3 m 13 s. |
| Reproducibility | 4.3.6 | | The response times of the point heat detectors lie between the lower ad upper response time limits specified in Table 2 above. |
| **Response delay (response time):** | | | |
| Additional test for suffix S point heat detectors | 4.4.1 | | Suffix S point heat detector did not exceed the lower limits of response time during the transer period or during the 10 min exposure below. |

| Point heat detector category | Conditioning Temperature °C | Airflow Temperature °C |
|---|---|---|
| A2S | 5 ±2 | 50 ±2 |

| Rate of rise of air temperature K $min^{-1}$ | Lower Limit response time | |
|---|---|---|
| | Min | S |
| 3 | 9 | 40 |
| 5 | 5 | 48 |
| 10 | 2 | 54 |
| 20 | 1 | 27 |
| 30 | | 58 |

| | | | |
|---|---|---|---|
| Additional test for suffix R point heat detectors | 4.4.2 | | N/A |
| **Tolerance to supply voltage:** | | | |
| Variation in supply parameters | 4.5 | | The point heat detector does not unduly depent on variation in the supply parameters and lie between the lower and upper response time limits specified in Table 2 above. |
| **Durability of nominal activation conditions/Sensitivity:** | | | |
| temperature resistance | | | |

apollo

| | | | |
|---|---|---|---|
| Cold (operational) | 4.6.1.1 | | No alarm or fault signal was given during the transition to the conditioning temperature or during the period at the condition temperature<br><br>Response time at 3 K $min^{-1}$ was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.<br><br>A2S: 20 K $min^{-1}$ was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6 |
| Dry heat (endurance) | 4.6.1.2 | | No fault signal was given on reconnection attributable to the endurance conditioning<br><br>Response time at 3 K $min^{-1}$ was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.<br><br>A2S: 20 K $min^{-1}$ was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6 |
| Humidity resistance | | | |
| Damp heat, cyclic (operational) | 4.6.2.1 | | No alarm or fault signal was given during the conditioning.<br><br>Lower temperature: (25±3) °C<br>Upper temperature: (40±2) °C<br><br>Relative humidity:<br>At lower temperature :≥ 95 %<br>At upper temperature : (93 ±3) %<br><br>Response time at 3 K $min^{-1}$ was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.<br><br>A2S: 20 K $min^{-1}$ was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6 |
| Damp heat, steady-state (endurance) | 4.6.2.2 | | No fault signal was given on reconnection attributable to the endurance conditioning.<br><br>Conditioning<br>Temperature : 40 ±2 °C<br>Relative Humidity: 93 ±3 %<br>Duration : 21 days<br><br>Response time at 3 K $min^{-1}$ was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.<br><br>A2S: 20 K $min^{-1}$ was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6 |
| Corrosion resistance | | | |
| Sulphur dioxide ($SO_2$) corrosion (endurance) | 4.6.3 | | No fault signal was given on reconnection attributable to the endurance conditioning.<br><br>Conditioning<br>Temperature : 25 ±2 °C<br>Relative Humidity: 93 ±3 %<br>SO2 concentration: 25 ±5 ppm (by volume)<br>Duration : 21 days<br><br>Response time at 3 K $min^{-1}$ was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.<br><br>A2S: 20 K $min^{-1}$ was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6 |
| Vibration resistance | | | |
| Shock (operational) | 4.6.4.1 | | No alarm or fault signal was given during the conditioning period or an additional 2 min. |

| | | | |
|---|---|---|---|
| | | | For specimen with a mass ≤ 4,75 kg :<br><br>Shock pulse type: Half sine<br>Pulse duration : 6 ms<br>Peak acceleration: 10X (100-20M) ms-2 (M is specimen mass in Kg)<br>Number of directions: 6<br>Pulses per direction: 3<br><br>Response time at 3 K $min^{-1}$ was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.<br><br>A2S: 20 K $min^{-1}$ was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6 |
| Impact (operational) | 4.6.4.2 | | No alarm or fault signal was given during the conditioning period or an additional 2 min.<br><br>Conditioning:<br>Impact energy: 1,9 ±0,1 J<br>Hammer velocity: 1,5 ±0,13 $ms^{-1}$<br>Number of impacts: 1<br><br>Response time at 3 K $min^{-1}$ was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.<br><br>A2S: 20 K $min^{-1}$ was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6 |
| Vibration, sinusoidal (operational) | 4.6.4.3 | | No fault signal was given during the conditioning<br>Conditioning:<br>Frequency range: 10 to 150 Hz<br>Acceleration amplitude: 5 $ms^{-2}$(≈0,5 $g_n$)<br>Number of axes : 3<br>Sweep rate: 1 octave $min^{-1}$<br>Number of sweep cycles: 1 per axis<br><br>Response time at 3 K $min^{-1}$ was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.<br><br>A2S: 20 K $min^{-1}$ was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6 |
| Vibration, sinusoidal (endurance) | 4.6.4.4 | | No fault signal was given on reconnection attributable to the endurance conditioning.<br><br>Conditioning:<br>Frequency range: 10 to 150 Hz<br>Acceleration amplitude: 10 $ms^{-2}$(≈1,0 $g_n$)<br>Number of axes : 3<br>Sweep rate: 1 octave $min^{-1}$<br>Number of sweep cycles: 20 per axis<br><br>Response time at 3 K $min^{-1}$ was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.<br><br>A2S: 20 K $min^{-1}$ was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6 |
| Electrical stability EMC immunity (operational) | 4.6.5 | | Compliance in EN 50130-4:2011 and No fault signal was given during the conditioning.<br><br>Response time at 3 K $min^{-1}$ was not less than 7 min 13 s and did not exceed 2 min 40 s compared with the time obtained in 4.3.6.<br><br>A2S: 20 K $min^{-1}$ was not less than 1 min and did not exceed 30 s compared with the time obtained in 4.3.6 |

## 8 Online Display Location

This document can be viewed online at www.apollo-fire.co.uk

The performance of the product identified above is in conformity with the set of declared performance/s.
This declaration of performance is issued, in accordance with The Construction Products Regulation 2011 (retained EU law EUR 305/2011) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, under the sole responsibility of the manufacturer identified above

Signed for and on behalf of Apollo Fire Detectors Limited by:

Mr. David Robbins
Technical Director
Havant - 26.03.2025

(v2)